

Government of Andhra Pradesh

A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
Regional Fire Officer
Zone-2,Rajahmundry
Andhra Pradesh.

To:
District Educational Officer,

File No: 28143/KRI/RFO/2025, Date:28/09/2025
Occupancy NoC RC Number: 19525/KRI/RFO/2023

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of St.Anthony ' English Medium School (Sr.Kusum , R.s. No. 653/1,2,3,3A), represented by Sr.Kusum, St.Anthony ' English Medium School (Sr.Kusum , R.s. No. 653/1,2,3,3A) , ATKURU . - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 19525/KRI/RFO/2023, Dt.04/09/2023
 4. Renewal NOC For Occupancy 19525/KRI/RFO/2023, Dt.29/10/2024
 5. Online Application for Renewal NOC of Sr.Kusum, St.Anthony ' English Medium School (Sr.Kusum , R.s. No. 653/1,2,3,3A) , ATKURU . - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 26-09-2025.

-- x --

The Management of St.Anthony ' English Medium School (Sr.Kusum , R.s. No. 653/1,2,3,3A), represented by Sr.Kusum, St.Anthony ' English Medium School (Sr.Kusum , R.s. No. 653/1,2,3,3A) , ATKURU . has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.25827/- vide challan No. 81267844252024, Dated 05/10/2025 at SBI, Gannavaram.

St.Anthony 's English Medium School

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate Sr.Kusum St.Anthony ' English Medium School (Sr.Kusum , R.s. No. 653/1,2,3,3A) , ATKURU ., subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.

2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.


4. This Periodical Renewal Fire Certificate is valid from 28/09/2025 to 27/09/2028.


5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
81267844252024	05/10/2025	25827

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.


Principal
ST. ANTHONY'S E.M. SCHOOL
ATKUR, Ungutur Mandalam,
Krishna Dist., A.P.



Manager
St. Anthony's E.M. High School
Ungutur Mandal, Atkur, A.P.

The Inspection committee consists of DDRFO-Krishan and FSIO-Gannavaram Fire Station have inspected the premises and offered the inspection remarks as Recommended : Namaskaram Sir, We have conducted an inspection of the premises of St. Anthony's English Medium School (Contact: Sr. Kusum), located at R.S. No. 653/1, 2, 3, 3A, Atkuru. (1).The building has a total height of 11.40 meters and falls under Educational Occupancy. (2). Povid set-backs, Open spaces & Means of escape are adequate and as per the required norms. (3).The firefighting equipment installed on the premises was found in proper working condition at the time of inspection. Hence, the issuance of the Annual Fire Safety Certificate for the said occupancy is recommended.

The Management has been advised to impart training to 40% of the Occupants and employees working at the Building in 3 days Basic course training in Fire prevention and firefighting at A.P. State/Regional Training Institute or at local Fire Station level within 3 months and compliance the particulars of trained Occupants and employees.

It shall be the responsibility of the Management to ensure that the installed fire-fighting equipment is maintained in working condition 24/7. In case of failure, the Management/Occupier/Owner will be held liable under the relevant laws in force.

Your Sincerely,


Regional Fire Officer
Zone-2, Rajahmundry
Andhra Pradesh.


Copy to Sr.Kusum, Sr.Kusum , St.Anthony ' English Medium School , Atkuru , Unguturu Mandal, Krishna District.


Copy to Chief Office for Record Purpose

Copy to District Fire Officer Concerned

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned


PRINCIPAL
ST. ANTHONY'S E.M. HIGH SCHOOL
ATKUR, Ungutur Mandalam,
Krishna Dist. A.P.


Manager
St. Anthony's E.M. High School
Ungutur Mandal, Atkur, A.P.